



U.S. Environmental Protection Agency

Region 5

Waste, Pesticides and Toxics Division

Program Management Branch

Underground Storage Tank Section

Have You Checked Your Tank Systems Today?

C H E C K L I S T

- ✓ **SPILL PROTECTION**
(Maintain sump free of liquids)
- ✓ **OVERALL PROTECTION**
(Check alarms and automatic Shutoff devices)
- ✓ **CORROSION PROTECTION**
(Tank and Piping)
 - Galvanic**
 - Within 6 months of installation
 - Every 3 years after installation
 - Impressed Current**
 - Within 6 months of installation
 - Every 3 years after installation
 - Check rectifier operation every 60 days
- ✓ **RELEASE DETECTION**
 - Monthly monitoring
 - Annual piping test and line leak detector tests
 - Daily inventory
 - Statistical Inventory Reconciliation
 - Automatic Tank Gauging
 - Other Approved Methods
- ✓ **MAINTENANCE**
 - Daily Systems Check
 - Periodic Equipment check
 - Dispenser Sumps
 - Liquid Level Sensors
 - Piping and Tank Sumps
- ✓ **RECORD KEEPING**
 - Tank and piping tightness test (5 years)
 - Performance claims for release detection (5 years)
 - Sampling, testing, monitoring (1years)
 - Calibration, maintenance and repair of release detection equipment (1 year)



If you have any questions please contact us at (312) 886-6159